[1] # EU-TYPE EXAMINATION CERTIFICATE

[2] **Equipment or Protective System intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU**

[3] EU-Type Examination Certificate Number: **UL 22 ATEX 2446X Rev. 3**

[4] Product : **Elexant 5010i & Elexant 5010i-LIM**

[5] Manufacturer : **Chemelex Belgium NV**

[6] Address : **Research Park Haasrode – Zone 2, Romeinse straat 14, B-3001 Leuvan, Belgium**

[7] This product and any acceptable variation thereto are specified in the schedule to this certificate and the documents therein referred to.

[8] UL International Demko A/S, notified body number 0539 in accordance with Article 17 of the Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres, given in Annex II to the Directive.
The examination and test results are recorded in the confidential report no. **US/UL/ExTR22.0039/03.**

[9] Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN IEC 60079-0:2018
EN 60079-7:2015
EN IEC 60079-7:2015/A11:2024
EN 60079-18:2015
EN 60079-31:2014
EN IEC 60079-0:2018/A11:2024
EN IEC 60079-7:2015/A1:2018
EN 60079-11:2012
EN 60079-18:2015/A1:2017

Where additional criteria beyond those given here have been used, they are listed at item 18 in the Schedule

[10] If the sign "**X**" is placed after the certificate number, it indicates that the product is subject to the "Specific Conditions of Use" listed under item 17 of this certificate.

[11] This EU-Type Examination Certificate relates only to the technical design of the specified product in accordance to the Directive 2014/34/EU. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by the certificate.

[12] The marking of the product shall include the following (marking is provided in the Schedule as a part of item 15, if applicable):

II 2 G Ex eb ib mb [ib] IIC T4 Gb

II 2 D Ex tb [ib] IIIC T67°C Db IP66

Certification Manager
Thomas Wilson

This is to certify that the sample(s) of the Product described herein ("Certified Product") has been investigated and found in compliance with the Standard(s) indicated on this Certificate, in accordance with the ATEX Product Certification Program Requirements. This certificate and test results obtained apply only to the product sample(s) submitted by the Manufacturer. UL did not select the sample(s) or determine whether the sample(s) provided were representative of other manufactured product. UL has not established Follow-Up Service or other surveillance of the product. The Manufacturer is solely and fully responsible for conformity of all product to all applicable Standards, specifications, requirements or Directives. The test results may not be used, in whole or in part, in any other document without UL's prior written approval.

Date of issue: 2023-04-06
Re-issued: 2026-02-25

Notified Body UL International Demko A/S, Borupvang 5A, 2750 Ballerup, Denmark
Tel. +45 44 85 65 65, info.dk@ul.com, www.ul.com

This certificate may only be reproduced in its entirety and without any change. Information about previous revisions of this certificate can be requested by contacting info.dk@ul.com.

[13] [14]

Schedule
EU-TYPE EXAMINATION CERTIFICATE No.
UL 22 ATEX 2446X Rev. 3

[15] Description of Product

The Elexant 5010i-LIM Heat-Tracing Temperature Control Unit with Intelligent Safety Limiter, rated at 100V to 250V and up to 25A, comprises a certified eb tb IP66 plastic enclosure into which are encapsulated a number of printed circuit boards. Termination facilities are provided within the enclosure, above the level of the encapsulation, for the connection of power supply, external RTDs, alarm and data transmission facilities.

The encapsulated parts are divided into intrinsically safe and non-intrinsically safe circuits, with their associated segregated Ex ib and Ex eb termination facilities above the encapsulant.

Internal connections provided from the encapsulated printed circuit boards for three external resistance thermal detectors (RTDs), are made to Ex ib (RTD) terminals situated at the other side of the enclosure and are segregated from the non-intrinsically safe terminals. Internal connections from the encapsulated printed circuit boards supply a four-digit seven segment LED display, five indicator LEDs and two internal push button switches. All are mounted on a separate unencapsulated display printed circuit board behind a window in the lid of the enclosure.

An internal plastic cover provides an IP30 separation between the intrinsically safe display printed circuit board and the non-intrinsically safe termination facilities located on the terminal printed circuit board. A common Earth Terminal is provided adjacent to the Ex ib (RTD) terminals for the termination of cable screens.

External connection is provided via cable entry threaded holes, which enter the enclosure above the level of the encapsulation. Internal and external earthing facilities are provided. For Safety Parameters, refer to Certificate Annex.

A variation on the Elexant 5010i-LIM Heat-Tracing Temperature Control Unit with the safety limiter components omitted is given the designation: Elexant-5010i Heat-Tracing Temperature Control Unit. This unit omits all components associated with RTD3 and its associated internal switches.

Temperature range
The ambient temperature range is -50°C to +60°C.

Electrical data
100-250Vac, 47/63Hz, 25A max

Intrinsically safe specifications:
U_m : 250 V

RTD1, RTD2, or RTD3-LIMITER per channel:
U_o : 5.88 V
I_o : 0.089 A
P_o : 0.131 W
L_o : 4488 uH
C_o : 42.7 uF

Routine tests

- Each piece of “m” equipment shall be subjected to a visual inspection. No damage shall be evident, such as cracks in the compound, exposure of the encapsulated parts, flaking, inadmissible shrinkage, swelling, decomposition, failure of adhesion (separation of any adhered parts) or softening.
- Each manufactured sample of equipment shall be subjected to an electric strength test using a test voltage per table below. The test voltage shall be increased steadily within a period of not less than 5 s until it reaches the prescribed value, and it shall then be maintained for at least 2 s.

Description	Test Voltage
Input L&N, Output L&N and Alarm relay contact shorted together to grounding stud and RS-485 pins shorted together	2200Vac or 3100Vdc

[16] Descriptive Documents

The scheduled drawings are listed in the report no. provided under item no. [8] on page 1 of this EU-Type Examination Certificate.

[17] Specific conditions of use:

- Cable entry shall be Ex eb and tb ATEX certified and rated minimum IP66 to maintain the IP66 rating of the enclosure. Cable entry devices must have a seal or gasket to provide sealing with the enclosure.
- Unused cable entries must be filled with Ex eb and tb ATEX certified and rated minimum IP66 stopping plugs to maintain the IP66 rating of the enclosure. Cable entry plugs must have a seal or gasket to provide sealing with enclosure.
- Not more than one single or multiple strand wiring lead shall be connected into either side of the terminals.
- Leads connected to the terminals shall be insulated for the appropriate voltage and this insulation shall extend to within 1mm of the metal of the terminal throat.
- The maximum permitted current of the non-IS alarm contacts is 3A.
- The earth pillar adjacent to the RTD connectors must be used only for RTD cable screens.
- The external RTDs must be capable of withstanding a 500V test to earth.

This certificate may only be reproduced in its entirety and without any change. Information about previous revisions of this certificate can be requested by contacting info.dk@ul.com.

[13] [14]

Schedule
EU-TYPE EXAMINATION CERTIFICATE No.
UL 22 ATEX 2446X Rev. 3

[18]

Essential Health and Safety Requirements

The Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9.

Additional information

The trademark Raychem will be used as the company identifier on the marking label.

The manufacturer shall inform the notified body concerning all modifications to the technical documentation as described in Annex III to Directive 2014/34/EU of the European Parliament and the Council of 26 February 2014.

This certificate may only be reproduced in its entirety and without any change. Information about previous revisions of this certificate can be requested by contacting info.dk@ul.com.