1 # TYPE EXAMINATION CERTIFICATE

2 **Intrinsically Safe System Intended for use in Potentially Explosive Atmospheres**

3	Type Examination Certificate Number:	**Baseefa11Y0277 Issue 3**
4	System:	**TraceTek TT-TAR Leak Detection System**
5	Certificate Holder:	**Chemelex LLC**
6	Address:	**899 Broadway Street, CA, 94063-3104 United States of America**

7 This system and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

8 SGS Baseefa certifies that this system has been found to comply with the following standards

EN 60079-25: 2010

This certificate issue is for the sole purpose of recording a change to the certificate holder's name/address. A technical review has not been undertaken and the standards remain at the editions listed previously.

9 The examination and test results are recorded in confidential Report No's. **See Certificate History.**

10 If the sign "X" is placed after the certificate number, it indicates that the system is subject to special conditions of safe use specified in the schedule to this certificate.

11 This TYPE EXAMINATION CERTIFICATE relates only to the design of the specified intrinsically safe system and not to specific items of equipment therein**.** It is the responsibility of the system certificate holder to supply the relevant documentation to the installer of the intrinsically safe electrical system referred to in this certificate.

The installer has the responsibility to ensure that the system conforms to the specification laid down in the Schedule to this certificate and has satisfied routine verifications and tests specified therein.

12 The marking of the system shall include the following :

Ex ia IIA T4

SGS Customer Reference No. **0865** Project File No. **25/0111**

This document is issued by the Company subject to its General Conditions for Services and Certification Services accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and the Supplementary Terms and Conditions accessible at http://www.sgs.com/SGSBaseefa/Terms-and-Conditions.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS United Kingdom Ltd.
Rockhead Business Park, Staden Lane,
Buxton, Derbyshire SK17 9RZ
Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601
e-mail baseefa@sgs.com web site www.sgs.co.uk/sgsbaseefa
Registered in England No. 4305578.
Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN

UKAS PRODUCT CERTIFICATION
0191

On behalf of SGS United Kingdom Ltd.

13 # Schedule

14 ## Certificate Number Baseefa11Y0227 – Issue 3

15 System Description

The TraceTek TT-TAR Leak Detection System is designed to detect the presence of hydrocarbons, organic solvents, mineral acids or conductive fluids that may be leaking from a storage vessel or pipe. If a leak is detected a signal is sent to the safe area equipment so that the appropriate action can be taken.

The system consists of an MTL-5541 repeater power supply Located in the Safe Area, and a TraceTek TT-TAR Transducer with, up to 4 TraceTek TT-FFS Fast Fuel Sensors or up to 300m of either TT-3000, TT-5000, TT-5001 or TT-7000 Sensing Cables with optional end of line TT-MINI-PROBE located in the Hazardous Area. The sensing cables are for the detection of Conductive Fluids, Hydrocarbon Sensing Cable, Organic Solvents or Strong Mineral acids. In the event of a leak the Hazardous area equipment will relay a signal via the MTL-5541 isolator to equipment in the safe area.

1. Apparatus that may be installed in a Non Hazardous Area (Safe Area.)

1.1 MTL 5541 Repeater Power Supply

1.2. The above apparatus is to be supplied from apparatus situated in the safe area which is unspecified except that it must not be supplied from nor contain in normal or abnormal conditions a source of potential with respect to earth in excess of 253 volts r.m.s. or 253 volts d.c.

2. Apparatus that may be installed in a Hazardous Area

2.1 A TraceTek TT-TAR Transducer and either, up to 4 TraceTek TT-FFS Discrete Fuel Sensors or up to 500m of TT-3000, TT-5000, TT-5001 or TT-7000 Sensing cable with optional end of line Mini Probe.

3. Permissible Interconnecting Cables

3.1 The capacitance and either the inductance or the inductance to resistance ratio (L/R) of the hazardous area cables must not exceed the following values:-

4 TT-FFS Fast Fuel Sensors

C µF	L mH	OR	L/R Ratio µH/Ω
0.86	40		469

500m of Sensing Cable including optional Mini Probe

C µF	L µH	OR	L/R Ratio µH/Ω
1.6	40		469

3.2 Wiring to terminals of the safe area apparatus may be achieved by separate cables or by separate circuits within a Type A or Type B multicore cable (as defined in clause 5.3 of EN50 039) subject to the following:-

a. The circuit to be individually screened when used within a Type A multicore cable.
b. The peak voltage of any other circuit within a Type B multicore cable must not exceed 60V.

16 Report Number

See Certificate History.

17 Specific Conditions of Use

None

18 Essential Health and Safety Requirements

In addition to the Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9, any additional relevant EHSRs are dealt with in the certificates for the apparatus forming part of this system

19 Drawings and Documents

New drawings submitted for this issue of certificate.

None.

Current drawings also associated with this certificate.

Number	Sheet	Issue	Date	Description
1012-2535	1 of 1	E	25-FEB-2018	TraceTek TT-TAR System Approval Label
1012-2524	2	D	08-SEP-2014	TT-TAR Apparatus Control Drawing

These drawings are common to IECEx BAS 11.0142

20 Certificate History

Certificate No.	Date	Comments
Baseefa11Y0277	21 May 2012	The release of the prime certificate. The associated test and assessment is documented in Test Report No. GB/BAS/ExTR12.0092/00.
Baseefa11Y0277 – Issue 1	29 October 2014	To permit the addition of alternative sensing cable to be used in the system, types TT-3000 and TT-7000 To permit the addition of an optional end of line low point liquid leak detection probe. To permit modification of the marking label. The associated test and assessment is documented in Test Report No. GB/BAS/ExTR12.0248/00.
Baseefa11Y0277 – Issue 2	17 January 2019	To confirm the certificate is now held in the name of nVent Thermal LLC. To update the product marking label to show the name of nVent Thermal LLC. SGS Baseefa certification report GB/BAS/ExTR18.0123/00 refers.
Baseefa11Y0277 – Issue 3	18 November 2025	The issue of this certificate permits existing information (for example on Certificate Schedule Drawings or label marking) to be updated to show the new name, no other changes may be made to the certified design. A technical review has not been undertaken, and the standards remain at the editions listed previously. Report Number: None Project Number: 25/0111
For drawings applicable to each issue, see original of that issue.		